

I hope you had a great easter weekend and were able to take advantage of (some of) the sunshine!

Please see last week's update, which is belated due to the bank holidays:

The catchment levels are continuing to drop, even with the heavy rainfall documented on Friday 3rd April.

The remedial plan is still being put together with our manhole sealing team to reduce infiltration that is entering the network via the private inspection chambers we identified.

At this stage, we have **not** identified any failed sewer sealing works.

Progress Update:

- **The crews sealed approximately 123m of public and private sewer in Singleton and East Dean last week.**
- **This brings the total sealed to date to around 12,213m across both public and private sewer networks.**

Aside from the above, it's business as usual as we continue progressing with the task at hand.


I've also included the **borehole data from Chilgrove** below which shows the ground water levels for your reference.

Borehole	Latest level	Date
Chilgrove	60.469	7 Apr 2026

Date ▲		Rise (or fall) in the last 24 hours (m)
3 Apr 2026, 00:00	↓	-0.291
4 Apr 2026, 00:00	↓	-0.384
5 Apr 2026, 00:00	↓	-0.347
6 Apr 2026, 00:00	↓	-0.384
7 Apr 2026, 00:00	↓	-0.328

LockerStudio

Chilgrove Rainfall



The ground water continues to fall and we will monitor this to find more localised issues created by this years ground water season.

We will continue to investigate and fix as we find the issues as quickly as possible to get the tankers away from the catchment.