

Please see this weeks update.

For ease of reading all significant updates are highlighted in red.

Sewer lining works were on hold this past week due to the activities around Mental Health Awareness Week. These works will commence again from Monday.

The surveying of all the sealing works undertaken to date will continue, with MTS now carrying out CCTV investigation downstream from East Dean to West Dean. To allow for the best possible results, a jetting unit will also be in tow to clean the line where applicable.

At this stage, we have **not identified any failed sewer sealing works.**

Once our surveys are complete, we will discuss a remedial plan with our manhole sealing team to reduce infiltration that is entering the network via the private inspection chambers we identify.

Progress Update:

- **The total sealed to date remains the same due to the aforementioned at 13,062m across both public and private sewer networks.**

Charlton & Singleton and West Dean:


Thank you to those who attended meetings in Charlton & Singleton and West Dean on Wednesday evening. We appreciated your time and the productive questions raised. We look forward to seeing you again soon and discussing further progress and findings.

I've also included the borehole data from Chilgrove below which shows the ground water levels for your reference.

Borehole	Latest level	Date
Chilgrove	49.796	15 May 2026

Date	Rise (or fall) in the last 24 hours (m)
11 May 2026, 00:00	-0.19
12 May 2026, 00:00	-0.228
13 May 2026, 00:00	-0.214
14 May 2026, 00:00	-0.232
15 May 2026, 00:00	-0.171

Chilgrove Rainfall



The ground water continues to fall and we will monitor this to find more localised issues created by this years ground water season.

We will continue to investigate and fix as we find the issues as quickly as possible to get the tankers away from the catchment.