

Please see the latest update for the catchment.

The catchment levels are continuing to drop, in fact over the last 3 weeks they have dropped by around 5m.

A remedial plan is still being put together with our manhole sealing team to reduce infiltration that is entering the network via the private inspection chambers we identified.

At this stage, we have **not** identified any failed sewer sealing works.

Please note that Glenn is on A/L next week.

Progress Update:

- **The crews have sealed approximately 233m of public and private sewer in Singleton and East Dean this week.**
- **This brings the total sealed to date to around 12,090m across both public and private sewer networks.**


Aside from the above, it's business as usual as we continue progressing with the task at hand.

I've also included the **borehole data from Chilgrove** below which shows the ground water levels for your reference.

Borehole	Latest level	Date
Chilgrove	64.446	27 Mar 2026

Date ^		Rise (or fall) in the last 24 hours (m)
23 Mar 2026, 00:00	↓	-1.308
24 Mar 2026, 00:00	↓	-0.291
25 Mar 2026, 00:00	↓	-0.338
26 Mar 2026, 00:00	↓	-0.384
27 Mar 2026, 00:00	↓	-0.387

Chilgrove Rainfall



The ground water continues to fall and we will monitor this to find more localised issues created by this years ground water season.

We will continue to investigate and fix as we find the issues as quickly as possible to get the tankers away from the catchment.